



ADDENDUM No. "2" to RFP No. B2015004

Emergency Generators – All Courts

Date of Addendum No. "2" Issued: March 16, 2015

Purpose of this Addendum is to

Respond to questions received.

1. What are your expectations for the length of the simulated power outage test for each generator? *4 hours*
2. Do you pay EPA fees, when battery changes are required? *Yes*
3. Is there a minimum on service call charges (i.e. 2 hour minimum vs. time on site only)? *We pay for on-site time only.*
4. Do you pay freight on parts for service calls/ repairs? *Only if the part is not in stock and there is a need for quick shipments.*
5. Can you provide a more detailed list of equipment, to include at least the KW size and fuel type? *You must visit the site.*
6. We would like to schedule the site visit for next Tuesday, March 17th. Do we need to schedule that with Richard Blakely at 401-222-6700? *Yes.*